

Water Source

We serve more than 13,876 customers an average of 2,712,900 gallons of water per day. Our water is groundwater that we produce from local wells. The state has performed an assessment of our source water and they have determined that the relative susceptibility rating for the Pierre public water supply system is medium.

For more information about your water and information on opportunities to participate in public meetings, call (605)773-2298 and ask for Lynn Patton or (605)773-7448 for Dane Brewer.

Additional Information

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.*
- *Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.*
- *Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.*
- *Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.*
- *Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.*

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants can be obtained by calling the Environment Protection Agency's Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City of Pierre public water supply system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Detected Contaminants

The attached table lists all the drinking water contaminants that we detected during the 2008 calendar year. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done January 1 – December 31, 2008. The state requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, is more than one year old.

Violations

Your system had violations in 2008. Please see the attached Table of Violations for information concerning these violations.

2008 Drinking Water Report

It's your tap water!

Last year, the City of Pierre monitored your drinking water for more than 80 possible contaminants. This brochure is a snapshot of the quality of the water that we provided last year. Included are details about where your water comes from, what it contains, and how it compares to Environmental Protection Agency (EPA) and state standards. We are committed to providing you with information because informed customers are our best allies.



<http://ci.pierre.sd.us>
(605)773-7341

2008 Table of Detected Contaminants For Pierre (EPA ID 0242)

Terms and abbreviations used in this table:

* *Maximum Contaminant Level Goal(MCLG): the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.*

* *Maximum Contaminant Level(MCL): the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.*

* *Action Level(AL): the concentration of a contaminant which, when exceeded, triggers treatment or other requirements which a water system must follow.*

* *Treatment Technique(TT): A required process intended to reduce the level of a contaminant in drinking water. For turbidity, 95% of samples must be less than 0.3 NTU*

Units:

*MFL: million fibers per liter

*pCi/l: picocuries per liter(a measure of radioactivity)

*ppt: parts per trillion, or nanograms per liter

*mrem/year: millirems per year(a measure of radiation absorbed by the body)

*ppm: parts per million, or milligrams per liter(mg/l)

*ppq: parts per quadrillion, or picograms per liter

*NTU: Nephelometric Turbidity Units

*ppb: parts per billion, or micrograms per liter(ug/l)

*pspm: positive samples per month

Substance	Highest Level Detected	Range	Date Tested	Highest Level Allowed (MCL)	Ideal Goal (MCLG)	Units	Major Source of Contaminant
Arsenic	2	ND - 2	06/22/08	10	NA	ppb	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes.
Barium	0.090	0.080 - 0.090	04/18/07	2	2	ppm	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits.
Copper	1.2	#Sites>1.3 AL - 1	06/20/08	AL=1.3	0	ppm	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives.
Fluoride	2.0	0.9 - 2.0	11/04/08	4	4	ppm	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories.
Lead	3	#Sites>15 AL - 0	07/07/08	AL=15	0	ppb	Corrosion of household plumbing systems; erosion of natural deposits.
Tetrachloroethylene	0	0 - 3	06/11/08	5	0	ppb	Leaching from PVC pipes; discharge from factories and dry cleaners.
Trichloroethylene	0.59	0 - 1	06/11/08	5	0	ppb	Discharge from metal degreasing sites and other factories.

2008 Information on Violations For Pierre (EPA ID 0242)

Type	Parameter	Date	Health Effects Language	Action Taken By Your System
00102 DBP Failure To Monitor	Trihalomethane (THM)	01/01/2008	We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. Water samples collected for THM and HAA5 analysis were collected on 1 October 2008 but were required to be collected and reported before 30 September 2008. Although sample results were below MCL levels for these constituents, because they were obtained outside the recommended sampling window by one day they did not satisfy requirements set by EPA.The next sampling opportunity for these substances will occur in August 2009.	We have taken additional measures within the water system administration to be sure that samples are taken properly in the future.
00103 DBP Failure To Monitor	Haloacetic Acids (HAA5)	01/01/2008		

